

Document Issued By:	Patrick Graham	Document Number:	QF-8.2-05
Document Issue Date:		Document Revision Level:	Rev-3.3(05/25/07)

Dimplex

Thermal Solutions

DATAPACK

Quality Assurance Program

Serial Number: W005307 2/3/15

Model: SVI-2000-M



SerialNumber: W005307

Inventory Number: 800517

000 Tested By: Rick Evans

Voltage: 230

PH: 1

HZ: 60

Specifications

Specifications

Test	Range	Actual
Refrig Type	R407C	R407C
Fluid Type	Water	WATER
Fluid Operating Temp.	68F	68

Test	Range	Actual
Refrig Lbs	5	5
Ambient Temp.	50-95	72
Delta Temp.	---	6.6

Fan

Fan

Test	Range	Actual
RLA	---	2.4
L2	---	2.3

Test	Range	Actual
L1	---	2.2
L3	---	

Compressor

Compressor

Test	Range	Actual
High Pressure In/Out	/450	450 LL
Sub Cooling	---	10
BTU/HR	24,000	33500
Head Pressure	175-350	212
RLA	---	15.0
L2	---	5.7
Hot Gas Regulator (psi)	55	55

Test	Range	Actual
Low Pressure In/Out	50/25	50/25
Superheat (F)	15-20	17
Suction Pressure	65-90	87
Temp Set ON/OFF	68/65	68/65
L1	---	7.1
L3	---	

Pump

Pump

Test	Range	Actual
RLA	---	6.1
L1	---	4.9
L3	---	
Req'd Process Flow GPM	10	10

Test	Range	Actual
Service Factor	1.25	1.25
L2	---	5.0
O.L. Size	---	7.6
Req'd Actual Head Press	35	35

SerialNumber: W005307

Program

Program

	Test	Range	Actual		Test	Range	Actual
Program Number Installed		-----	CAREL EASY	Program Revision Installed		-----	
Software Version Installed		-----					

Notes: